



Combined Residential Domestic/Fire Service

Fire Sprinkler backflow prevention device

domestic cut-off IPC/IRC

1-1/4" min dia copper water service up to Backflow device

cut-off within 5' of water meter (HP amendment)

Backflow device located within 5' of domestic service tie-in ("T")

property line (or easement line)

